

Model FTI-5A



Engineering Specifications Automated Diesel Fuel Maintenance System Diesel Fuel Tanks Up To 15,000 Gallons

1. Diesel fuel storage tank shall be equipped with a **FM APPROVED**, and **NFPA COMPLIANT EQUIPMENT**, automated fuel maintenance system to remove particulate through 1 micron and 99.5% water from stored diesel fuel.
2. **Pump / Motor Ratings**
 1. Pump: 5-GPM, spur gear or rotary gear, mechanical seal, positive gear displacement.
 2. Motor: 1/2 HP, 120V AC @ 7.4 Amps, 1 phase, 60HZ, TEFC. **(208-240V AC @ 3.7 Amps Optional)**
3. **Filtration Shall Consist Of:**
 - Stage 1: 100 Wire Mesh Strainer (149 Micron Spin on Filter).
 - Stage 2: 10 Micron Particulate Removal (Spin on Filter).
 - Stage 3: 3 Micron Particulate Removal (Spin on Filter).
 - Stage 4: Water Separation and Removal (Element type).
 - Stage 5: 1 Micron Particulate Removal (Element type).

(All filters shall be spin-on removable and / or replaceable element types)
4. **Suggested Filter Replacement Kit: PN: FRK-5A**
(2 ea.) FL-30-100M, (2 ea.) FL-FBO-60327, (2 ea.) FL-30-10N, (2 ea.) FL-30-03N
5. **Controller Specifications:**
 1. Controller shall be a **UL LISTED, ASSEMBLY CONSISTING OF:**
 - A) **Siemens S7-224 PLC** - Inputs/Outputs: 24, Program Memory: 8 Kbytes, Bit Processing Time: 0.37 ms.
PLC Shall Monitor: 1. Motor Contactor and Overload, 2. Five Stages Filtration, 3. Leak Detection, 4. Water Level Sensor, 5. System Pressure, 6. Strainer Vacuum, 7. Flow (Flow or no Flow)
 - B) **Circuit Breaker** - 2 Pole, 16 Amp
 - C) **Lockable Disconnect Switch**
 - D) **Motor Contactor and Thermal Overload** -16 Amp, Single Phase, 120V AC, 1/3HP, Class 10
 - E) **Multi Pole Terminal Block** - 26 Amp, 18-12 AWG
 - F) **Siemens TP177 Touch Screen** – Siemens Windows Based Software, 50,000 Hrs, 32 Bit
 - G) **Signal Device (audible alarms)** - 120 VAC, Slow Pulse, 80 to 95 dB
 2. Controller is programmable to operate up to four (4) separate diesel fuel storage tanks.
 3. Controller is programmable to time delay the following operations:
 - (A) Turning on of the fuel circulation pump (1-90 seconds). Required for Actuated ball Valves.
 - (B) Closing of Solenoid Valves or Actuated Ball Valves (1-90 seconds)
 - (C) Alarm status delay. (1-90 seconds)
 - (D) Flow Alarm Delay 1-6 minutes. (default is 3 minutes)
 4. Controller includes an **audible alarm** and visual description for each alarm condition.
 5. Controller includes **two dry contacts** (one normally closed and one normally open) for remote **general alarm status**.
 6. **Optional- controller box strip heater** shall be a 50-watt, thermostat controlled, with UL component recognition (UR).
 7. Controller is capable of operating up to **(8) Solenoid valves** or **(8) Electric actuated ball valves**.
There are 4 relays, which operate 2 valves to each tank. One supply valve and one return valve per tank. (Actuated ball valves must have 2 internal-SPDT switches. The two switches will turn the motor off when it reaches the full open and the full closed position).

6. **Enclosure**

1. Complete FTI assembly is housed in a 2-door cabinet with **Zinc Primer for corrosion and then Powder Coat Finish (doors are removable)**.
Manufactured to NEMA 3R standards and designed for rack or wall mounting.
2. Cabinet size: 40.0" W x 43.25" H x 14.0" D
3. **Leak detection:** Provided in cabinet.
4. **Total System Shipping Weight: 300 lbs.**

7. **Electrical Connection**

120V AC, 1 Phase, 60 Hz, 15 Amps **(120V AC Standard) – (208 / 240V AC Optional)**
Equipment will be shipped as 120V AC Standard

8. **Plumbing**

1. The **supply** or suction line shall be installed at the **sump**, or low end of the Diesel Fuel storage tank, with a **Foot Valve**, 1" from the bottom.
2. The return line shall be installed to the opposite end of the storage tank.
3. Caution should be taken **not to exceed the 15-ft. lift** capability of the fuel circulation pump.
4. Should vertical suction lift exceed 15 ft., the circulation pump in FTI cabinet should be removed and replaced with a submersible pump in the storage tank. Submersible pump shall be wired to FTI control panel. A flow control valve and a flow meter supplied to adjust flow at 5 GPM.
5. **System Inlet Connection – 3/4" NPT connection**
6. **System Outlet Connection – 3/4" NPT connection**
7. **Minimum Suggested Supply Line Pipe Size: (1")**

INSTALLATION PRECAUTIONS:

IF POWER TO THE FTI CONTROL PANEL IS TO BE TURNED OFF AFTER IT IS INSTALLED, THEN THE INSTALLER SHALL PROVIDE FOR THERMAL EXPANSION PROTECTION.

AFTER INSTALLATION, BOTH OF THE MANUAL BALL VALVES IN THE FTI CABINET MUST REMAIN OPEN.

THE FTI CONTROL PANEL WILL AUTOMATICALLY OPEN ALL ELECTRICALLY CONNECTED VALVES WHEN THE PRESSURE GAUGE REACHES 45 PSI. THIS FEATURE OPERATES ONLY WHEN POWER IS ON AND THE CONTROL PANEL IS SET TO AUTO OR MANUAL OFF MODES

FTI WILL NOT BE RESPONSIBLE FOR ANY THERMAL EXPANSION DAMAGE DUE TO EXCESSIVE PRESSURE.

**Model FTI-5A as Manufactured by
Fuel Technologies International LLC
P O Box 6863, Santa Maria, CA 93456**